

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 7	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 190 - 789.0
 Issue Date: 10/20/2011
 Revision Date: 5/21/2021
 Expiration Date: 9/21/2024
 Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr., PO Box 1529 Nokomis, FL 34274 USA	Model: CD290 Cabana Full Lite Aluminum Outswing Door Operator Type: SHD Config: No, GS-1/8" Temp Mono Max Width: 37 Max Height: 81

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/IS2/A440-08	Class R-PG50 949x2051 (37x81)-Type SHD

Qualifying Test Information:	
Test Report No:	FTL-6631/6634
Test Report Expiration:	9/21/2024

Authorized Signature:

Keystone Certifications, Inc.
 145 Limekiln Rd. Suite 100B
 New Cumberland, Pennsylvania 17070
 Phone: 717-932-8500
 Fax: 717-932-8501